

High Bridge Wind Project

Case No. 18-F-0262

1001.38 Exhibit 38

Water Interconnection

EXHIBIT 38 WATER INTERCONNECTION

The proposed Facility is not expected to require water interconnection facilities. As a result, the requirements of 16 NYCRR § 1001.38 are not applicable. It is anticipated that the water supply needs for the operations and maintenance (O&M) facility will be satisfied through use of a private water well. The well will be drilled by a water well driller registered with the New York State Department of Environmental Conservation (NYSDEC) and will comply with all applicable NYSDEC requirements. Also, the system will conform to the standards set forth in 10 NYCRR Part 75, Standards for Individual Onsite Water Supply Systems.

Any surface or ground water withdrawal system used to supply water for the proposed temporary concrete batch plant, which will operate only during the construction phase, will have a withdrawal capacity of less than 100,000 gallons per day. As a result, no water withdrawal permit will be required under 6 NYCRR Part 601. See Exhibit 23 for additional information.