



America's Premier Competitive Power Company
... Creating Power for a Sustainable Future

Seismic Monitoring Advisory Committee Meeting

01 October 2019 to 31 March 2020 Reporting Period

Calpine Geothermal Visitors Center

Middletown, California

08 July 2020

Meeting Cancelled Due to COVID-19 Concerns

Craig Hartline


Senior Geophysicist

Calpine Corporation

The Geysers

Reporting Period: 01 October 2019 to 31 March 2020

- **Additional Seismic Monitoring and Research**



Seismic Monitoring Advisory Committee Meeting

Geysers Geothermal Field, Nearby Communities and Seismic Monitoring Networks


● **Lawrence Berkeley National Laboratory**
2003 installation; continuing upgrades
34 stations
Magnitude 0.8 Threshold *

● **Strong Motion Accelerometers**
● 2017/18 Nanometrics installation (2)
● 2020 Q1 Nanometrics installation (2)
0.1% of Gravitational Acceleration Threshold

● **US Geological Survey Regional Network**
1970's installation; several upgrades
7 contributing stations
Magnitude 1.5 Threshold *


Productive Steam
Reservoir Outline

"Major" Roads



Seismic Monitoring Advisory Committee Meeting

Geysers Geothermal Field, Top Granitic Intrusion and Top Steam Reservoir



Seismic Monitoring Advisory Committee Meeting

Status of Seismic Monitoring Networks

LBNL **Strong Motion** **USGS**

LBNL Seismic Monitoring Network
Fully Functional

The Department of Energy's Geothermal Technologies Office shifted their research efforts to these programs:

FORGE

Frontier Observatory for Research in Geothermal Energy Milford, Utah
<https://utahforge.com/>

EGS Collab

Geothermal technology research by eight national laboratories, six universities, and industrial partners.
<https://eesa.lbl.gov/projects/the-egs-collab-project/>

Why is this important?

Department of Energy funding for The Geysers seismic monitoring network ended May 2019.
Calpine now contributes \$110,000 for yearly maintenance and upgrades.

Ramsey Haught was previously contracted to LBNL for seismic monitoring network installation and maintenance.
This highly-experienced seismic specialist is now contracted directly by Calpine Corporation.
Jarpe Data Solutions* is also being contracted for data flow management tasks related to transition.

Calpine's Primary Seismic Monitoring Network Goal

Optimize LBNL network functionality, accuracy and reliability of prior to Ramsey's imminent retirement.
Optimize data flow from seismic data recovery, through data processing, and to efficient seismic data archival.

* Jarpe Data Solutions has long-term relationship with LBNL concerning seismic acquisition testing and seismic databases

Seismic Monitoring Advisory Committee Meeting

Status of Seismic Monitoring Networks

LBNL Strong Motion USGS

LBNL Seismic Monitoring Network



Recent Improvements

Calpine Purchased 24 Three-Component Geospace 2 Hz Sensors
Completed Installation for 22 of 24 By May 2020

Geospace HS-1 3C arrays and cables

Equipment: \$2,400 per sensor station
Installation: \$ 500 per sensor station
Total: \$2,900 per sensor station

“ideally suited for seismological, engineering, and scientific applications where passive, low noise, short period, tri-axial sensors are required”



Seismic Monitoring Advisory Committee Meeting

Status of Seismic Monitoring Networks

LBNL Strong Motion USGS

- **Geospace 2Hz Seismic Sensor Upgrades**
 - Completed Upgrade of 22 seismic monitoring stations to Geospace 2Hz sensors
- **Strong Motion Station Installation**
 - Completed Installation of two additional Nanometrics Titan accelerometer stations
Total of four on eastern perimeter near communities
- **Borehole Seismic Sensor Installation**
 - In Progress Determine optimal downhole seismic sensor for ~10 available shallow boreholes ($\leq 500'$ depth)
- **Battery Replacement and Recycle**
 - Completed Replacement Of 30 batteries At 15 LBNL seismic monitoring stations
2 Sunlyte / MK deep cycle batteries per station (36 purchased)
 - In Progress Additional battery replacements as required for remaining 23 stations
- **Hardware and Data Security**
 - Completed Replacement of outdated Taurus/Janus digitizers
Two LBNL servers now in Geysers Administration Center (one a back-up unit)
Uninterrupted Power Source at Geysers Administration Center
Uninterrupted Power Source at three radio repeater sites
(DX Radio Repeater, Socrates Container, Microwave Tower)
 - In Progress Power plant firewall / data security modifications
- **Software Upgrades**
 - Completed Improvements to web-based strong motion data interface
Improvements to strong motion waveform visualization software
 - In Progress Arranging software trial for Itasca InSite Geo software for refined seismic waveform analysis
- **Data Quality and Continuity**
 - Completed Transition to data transfer, processing and storage by Jarpe Data Solutions
Eliminate noise spikes on 2 Hz sensor data (grounding issue)
Replacement of cable for MIT-installed continuous GPS monitoring site TCH
 - In Progress Additional “state of health” tracking for data servers and seismic monitoring stations

Seismic Monitoring Advisory Committee Meeting

Status of Seismic Monitoring Networks

LBNL **Strong Motion** USGS

Strong Motion Monitoring Network

Recent Improvements

Calpine Purchased Four Nanometrics Titan Accelerometer Stations

All Now Installed And Operational Along Eastern Perimeter Of Geysers Geothermal Field

State-Of-The-Art Sensors Provide Improved Data Accuracy And Reliability

Nanometrics Titan Three- Component Accelerometer

Equipment: \$4,800 per sensor station

Installation: \$2,500 per sensor station

Total: \$7,300 per sensor station

Power

Solar Panels

Communications

LBNL Radio Telemetry

Data Reliability Concerns

Related To Previous Generation

ETNA Strong Motion Stations

Greatly Reduced

No Rural ...

AC Power

Phone-Line Communication



ACCELEROMETER TECHNOLOGY AND PERFORMANCE

Topology: Triaxial, horizontal-vertical

Feedback: Force balance with capacitive displacement transducer

Centering: Electronic offset zeroing via user interface or control line

Full-scale Range: Electronically selectable range: $\pm 4g$, $\pm 2g$, $\pm 1g$, $\pm 0.5g$, and $\pm 0.25g$ (peak)

Bandwidth: DC to 430 Hz (-3 dB point)

Dynamic Range: (Integrated RMS)

- 166 dB @ 1 Hz over 1 Hz bandwidth
- 155 dB, 3 to 30 Hz

Offset: Electronically zeroed to within $\pm 0.005g$


Non-linearity: < 0.015% total non-linearity

Hysteresis: < 0.005% of full scale

Cross-axis Sensitivity: < 0.5% total

Offset Temperature Coefficient:

- Horizontal sensor: $60 \mu g/^{\circ}C$, typical
- Vertical sensor: $320 \mu g/^{\circ}C$, typical



Seismic Monitoring Advisory Committee Meeting

Status of Seismic Monitoring Networks



LBNL **USGS** Strong Motion

USGS*/ Northern California Seismic Network

The USGS and collaborating agencies provide services of **significant value** to The Geysers.

The USGS Regional Seismic Network is responsible for these **fully functional** items:

Seismic Data	
Acquisition	Six three-component USGS seismic stations contribute to seismicity determinations within The Geysers.
Processing	Seismic waveforms are initially compiled and p-wave arrival times calculated at the USGS "Waveserver" located within the Geysers Administration Center (and adjacent to the LBNL seismic data server).
Transfer	Merged LBNL/USGS station waveforms and arrival times are forwarded by a Northern California Seismic Network radio link to their Geysers Peak microwave hub, then transmitted to the USGS facility at Menlo Park.
Integration	LBNL/USGS P-wave arrival times are integrated with P-wave arrival times from other monitoring networks operated by the USGS, UC Berkeley, the California Geological Survey, and the California Department of Water Resources.
Analysis	Automatic determination of seismic event magnitude, hypocenter, first-motion mechanisms, and moment tensor solutions/shake maps (for seismic events with magnitude > 3.5). Seismologists complete reviews of more significant events.
Distribution	The USGS Earthquake Hazards Program website (https://earthquake.usgs.gov/) is the starting point for access to almost unlimited seismicity information, including nearly "real-time" availability of earthquake information (https://earthquake.usgs.gov/earthquakes/map/).
Archival	Waveforms and event determinations retrieved hourly for archival at the UC Berkeley Northern California Earthquake Data Catalog. Data derived from this catalog, including tomographic double-difference refined seismicity hypocenter determinations, contributes to Calpine/NCPA seismicity analysis, along with worldwide seismic research collaborations.



* United States Geological Survey

Seismic Monitoring Advisory Committee Meeting

Kincade Fire Perimeter

The Kincade Fire began on 23 October 2019, resulting in limited seismic sensor station damage but significant central Geysers power and communications failures.


These failures strongly impacted seismic data transfer within The Geysers in subsequent months.

The most significant issue for the seismic monitoring network was damage to power and communications associated with the DX Radio Repeater Site.

The initial damage and facilities repairs resulted in many lengthy power and communication outages. Temporary generators, computer hardware relocations and data card swaps at 16 individual stations limited the seismic data loss, but gaps in the LBNL data stream were unavoidable.


The USGS seismic stations utilize a different communication network that was not significantly impacted by the Kincade Fire.

- Calpine Power Plants
- Calpine Facilities Of Interest
- Wellhead Locations
- LBNL Seismic Stations - Permanent
- CEC Research Seismic Stations - Temporary



Seismic Monitoring Advisory Committee Meeting

Kincade Fire



As a consequence of the Kincade Fire, all 54 **fieldwide** water injection wells and all 322 fieldwide steam production wells were initially “shut-in”. This is the only occurrence of a fieldwide shut-in experienced by Calpine employees.

LBNL Seismic Monitoring Network

- **Within Kincade Fire Perimeter**

Stations DRK, FUM, STY

STY fire-damaged; repairs required

DX Radio Repeater (east of DX 24 well pad)

Extensive power and communication loss

Primary collection point for 16 seismic stations

Secondary relay point for an additional 4 stations

Near Kincade Fire Perimeter

Stations PFR, JKB , FNF, SSR/SRB

No thermal damage detected

CEC Funded High-Resolution Seismic Network

- 20 of 93 temporary seismic stations within or very near perimeter

Only two CEC high-resolution stations damaged as they were:


- Sited in areas of limited vegetation for better solar exposure, and
- Placed on rock outcrops for better coupling

Seismic Monitoring Advisory Committee Meeting

Field-wide Seismicity Analysis

01 October 2019 to 31 March 2020


Magnitude	Number of Events
≥ 4.5	0
≥ 4.0	2
≥ 3.5	5
≥ 3.0	8
≥ 2.5	28
≥ 2.0	83
≥ 1.5	285



Seismic Monitoring Advisory Committee Meeting

SRGRP Daily Water Injection Volume and Fieldwide Seismicity

01 October 2019 to 31 March 2020




* Santa Rosa Geysers Recharge Project

Seismic Monitoring Advisory Committee Meeting

SRGRP Daily Water Injection Volume, Fieldwide Seismicity, Power/Communication Issues

01 October 2019 to 31 March 2020




* Santa Rosa Geysers Recharge Project

Seismic Monitoring Advisory Committee Meeting

SRGRP Daily Water Injection Volume, Fieldwide Seismicity, Power/Communication Issues


Detailed View of 13 October 2019 to 12 December 2019



Seismic Monitoring Advisory Committee Meeting


Field-wide Seismicity Analysis


Comparison of Twenty Semi-annual Reporting Periods Since 01 April 2010




Seismic Monitoring Advisory Committee Meeting

Yearly Field-wide Steam Production, Water Injection and Seismicity








Seismic Monitoring Advisory Committee Meeting


Yearly Field-wide Water Injection and Seismicity \geq Magnitude 2.5



Seismic Monitoring Advisory Committee Meeting

Yearly Field-wide Water Injection and Seismicity \geq Magnitude 3.0

The Geysers: Field-wide Water Injection and Seismicity \geq Magnitude 3.0
1960 through end 2019



Seismic Monitoring Advisory Committee Meeting


Monthly Field-wide Water Injection By Source vs. Magnitude ≥ 4.0 Seismicity

Average Number of Magnitude ≥ 4.0 Events Since January 2007 is 1.28 Per Year

Time Period	Magnitude ≥ 4.0 Seismic Events
January 2003 through December 2006	2.50 per year
January 2007 through March 2020	1.28 per year

Water Supply for Reporting Period (Six Months)				
Water Injection Sources (Gallons)				
Month	SEGP	SRGRP	Condensate	Fresh Water
October	72,216,000	153,050,000	171,568,358	0
November	49,551,000	0	140,045,165	0
December	87,037,000	442,460,000	283,000,798	0
January	30,692,000	544,140,000	251,887,538	6,488,180
February	5,706,000	436,550,000	234,830,792	27,202,634
March	94,522,000	450,910,000	357,515,784	0


The Geysers
Calpine Fieldwide Water Injection Sources
Magnitude ≥ 4.0 Seismicity
01 January 2000 through 31 March 2020



Seismic Monitoring Advisory Committee Meeting

Field-wide Seismicity Animation


Seismic Events Color Scaled By Magnitude



Seismic Monitoring Advisory Committee Meeting

Field-wide Seismicity Animation

Seismic Events Color Scaled By Depth



Seismic Monitoring Advisory Committee Meeting


Calpine Community Hotline

A relatively active six-month interval for seismicity, plus encouragement from Calpine to utilize the community hotline, resulted in a total of **18 calls** to the Calpine Community Hotline during the current reporting period of **01 October 2019 to 31 March 2020**.

The five seismic events of primary concern were:

- | | |
|--|---------------------------------|
| 03 November 2019 Magnitude 4.15 at 20:34:57 UTC
18,950' West-Northwest of Anderson Springs
45,000' West-Northwest of Middletown | 2 calls
1 call |
| 21 February 2020 Magnitude 2.81 at 02:33:21 UTC
11,410' West-Southwest of Anderson Springs | 2 calls |
| 08 March 2020 Magnitude 2.95 at 06:16:00 UTC
31,650' West-Northwest of Anderson Springs | 3 calls |
| 25 March 2020 Magnitude 4.06 at 11:57:38 UTC
18,640' Northwest of Anderson Springs | 4 calls |

The 25 March 2020 seismic event was of greatest concern to the community, due to a magnitude of 4.06 and a relatively limited epicentral distance.
(energy and distance are important criteria)



Seismic Monitoring Advisory Committee Meeting


Anderson Springs Engels Strong Motion ESM

Anderson Springs

Engels Strong Motion ESM

Left Graph Axis: HNE East-West; HNN North-South; HNZ Vertical


Right Graph Axis: Geometric Mean (% of Gravitational Acceleration)



Perceived Shaking	Not Felt	Weak	Light	Moderate	Strong	Very Strong	Severe	Violent	Extreme
Potential Damage	None	None	None	Very Light	Light	Moderate	Mod/Heavy	Heavy	Very Heavy
Peak Acceleration (% of g)	< 0.17	0.17 - 1.4	1.4 - 3.9	3.9 - 9.2	9.2 - 18.0	18.0 - 34.0	34.0 - 65.0	65.0 - 124.0	> 124.0
Peak Velocity (cm/sec)	< 0.10	0.1 - 1.1	1.1 - 3.4	3.4 - 8.1	8.1 - 16.0	16.0 - 31.0	31.0 - 60.0	60.0 - 116.0	> 116.0
Modified Mercalli Intensity	I	II-III	IV	V	VI	VII	VIII	IX	X

Seismic Monitoring Advisory Committee Meeting

Cobb Area Alder Creek Strong Motion ACR




Perceived Shaking	Not Felt	Weak	Light	Moderate	Strong	Very Strong	Severe	Violent	Extreme
Potential Damage	None	None	None	Very Light	Light	Moderate	Mod/Heavy	Heavy	Very Heavy
Peak Acceleration (% of g)	< 0.17	0.17 - 1.4	1.4 - 3.9	3.9 - 9.2	9.2 - 18.0	18.0 - 34.0	34.0 - 65.0	65.0 - 124.0	> 124.0
Peak Velocity (cm/sec)	< 0.10	0.1 - 1.1	1.1 - 3.4	3.4 - 8.1	8.1 - 16.0	16.0 - 31.0	31.0 - 60.0	60.0 - 116.0	> 116.0
Modified Mercalli Intensity	I	II-III	IV	V	VI	VII	VIII	IX	X

Seismic Monitoring Advisory Committee Meeting

Current Status Of 3D Structural Model Development

Selection: 01Jan1984_11June2019_NCEDC_TomoDD_FINAL

2019-08-01 18:00Z



Seismic Monitoring Advisory Committee Meeting

Fault/Fracture Interpretation Surfaces Based on Seismicity Alignments

April 2020: **327 Fault/Fracture Surfaces**

Greater than 40,000 interpreted points

Picked directly on aligned seismicity hypocenters

Picked using variously-oriented seismicity slices

Refinements during Pre-Drilling Well Analyses

Northwest Geysers


Primarily near vertical faults

Orientation consistent with regional stress

Southeast Geysers

More non-vertical faults


Several faults radiate from shallowest penetration of granitic intrusion (Felsite)



Seismic Monitoring Advisory Committee Meeting

Fault/Fracture Interpretation Surfaces Based on Seismicity Alignments

Azimuth Angle Visualized



Seismic Monitoring Advisory Committee Meeting

Interpretation of Significant Steam Entry 3D Alignments

Summary From Interpretation And Analysis

30 distinct significant (high pressure) steam entry 3D alignments identified and interpreted within SKUA GOCAD 3D project.

This analysis suggests primarily near-vertical SW-NE to W-E alignment orientations and secondarily near-vertical NW-SE alignment orientations for significant (high PSI) Geysers steam entries.
(representing open steam-filled fracture zones)

Steam production well drilling programs targeted to intersect the existing (interpreted) steam entry alignments may have a higher success rate - if sufficient separation exists to allow access to untapped productive steam reservoir.

Wells intersecting near-vertical SW-NE to W-E oriented fractures appear most likely to encounter high pressure steam.

This makes sense, as the regional stress field at The Geysers (N 23° E Maximum Horizontal Principal Stress) results in:
(1) northwest-to-southeast oriented faults/fractures consistent with the San Andreas Fault System, and
(2) southwest-to-northeast oriented potentially open faults/fractures due to transtensional forces

This analysis/interpretation may also assist in better understanding potential (or existing) water breakthrough from water injection wells to steam production wells along high permeability open fracture systems.

Seismic Monitoring Advisory Committee Meeting

Interpretation of Significant Steam Entry 3D Alignments

Additional Constraint For Well Planning And Seismicity Mitigation (?)



During several detailed pre-drilling project analyses (McKinley 17, LF51, GDC53B13, Prati 27) the following SKUA GOCAD 3D display changes were completed and noted to enhance significant steam entry alignments:

- 763 well segments displayed with **ONLY** steam entries (no wellhead symbol, well trajectory, other logs, markers, ...)
- Fieldwide relative scaling parameters for steam entries set with “no clip values”
(Range set as 0-431 psi; rather than 0-250 psi generally used to allow better distinction of lower psi steam entries)

These combined display parameters highlighted interesting alignments of the more significant steam entries in:

- **Map view**
- **Various orientations highlighting stream entry dip angles of up to approximately 30° from vertical**


The potential to use these interesting alignments in **well planning** and **water breakthrough** analyses is investigated.



Seismic Monitoring Advisory Committee Meeting

Interpretation of Significant Steam Entry 3D Alignments


Fieldwide Areas , Scaled Steam Entries and Colored-Scaled Top Steam Contours



Seismic Monitoring Advisory Committee Meeting

Interpretation of Significant Steam Entry 3D Alignments





Fieldwide Scaled Steam Entries Only



Seismic Monitoring Advisory Committee Meeting

Interpretation of Significant Steam Entry 3D Alignments


Developing Fracture Surfaces From Aligned Steam Entries



Seismic Monitoring Advisory Committee Meeting

Interpretation of Significant Steam Entry 3D Alignments


Fieldwide Scaled Steam Entries And 30 Significant Steam Entry Alignment Picks



Seismic Monitoring Advisory Committee Meeting

Interpretation of Significant Steam Entry 3D Alignments


Fieldwide Scaled Steam Entries And 30 Significant Steam Entry Alignment Fracture Surfaces



Seismic Monitoring Advisory Committee Meeting

Interpretation of Significant Steam Entry 3D Alignments




Fieldwide Scaled Steam Entries And 30 Significant Steam Entry Alignment Fracture Surfaces



Seismic Monitoring Advisory Committee Meeting

Interpretation of Significant Steam Entries 3D Alignment Analysis



Azimuth / Dip Analysis By Fracture Surface Schmidt Diagram Lower Hemisphere Mean Pole and Mean Circle




Seismic Monitoring Advisory Committee Meeting

Interpretation of Significant Steam Entries 3D Alignment Analysis


Azimuth / Dip Analysis By Fracture Surface Schmidt Diagram Lower Hemisphere Mean Pole and Mean Circle



Rose Azimuth



Rose Dip




Seismic Monitoring Advisory Committee Meeting


Interpretation of Significant Steam Entries

Azimuth / Dip Analysis For 30 Fracture Surfaces


Schmidt Diagram - Lower Hemisphere With Mean Poles



Rose Azimuth



Rose Dip




Seismic Monitoring Advisory Committee Meeting


Interpretation of Significant Steam Entries

Azimuth / Dip Analysis For 30 Fracture Surfaces


Schmidt Diagram - Lower Hemisphere With Fracture Surface Poles, Mean Poles And Mean Circles



Rose Azimuth



Rose Dip



Seismic Monitoring Advisory Committee Meeting


Interpretation of Significant Steam Entries

Schmidt Diagram - Lower Hemisphere With Fracture Surface Poles, Mean Poles And Mean Circles


This analysis suggests **primarily** near-vertical SW-NE to W-E alignment orientations and **secondarily** near-vertical NW-SE alignment orientations for aligned **significant (high PSI)** Geysers steam entries (representing open steam-filled fracture zones)

Steam production well drilling programs designed to intersect the existing (**interpreted**) steam entry alignments may have a **higher success rate** - if sufficient separation exists to allow access to untapped productive steam reservoir.


Wells intersecting near-vertical SW-NE to W-E oriented fractures appear most likely to (historically) encounter high pressure steam entries.



Rose Azimuth



Rose Dip





The regional stress field at The Geysers (N 23° E Maximum Horizontal Principal Stress) result in:
(1) northwest-to-southeast oriented faults/fractures consistent with the San Andreas Fault System, and
(2) southwest-to-northeast oriented **potentially open faults/fractures due to transtensional forces**
(regional stress field discussed on next slide)

Seismic Monitoring Advisory Committee Meeting

Interpretation of Significant Steam Entries

San Andreas Fault System and Resultant Stress Field

USGS/CGS Mapped Inactive Faults Zones



San Andreas Fault System

Extensive system of right-lateral strike-slip faults accommodates the relative motion between the Pacific Plate and North American Plate over a 60 to 180-mile-wide zone.

Successively smaller slip rates for active faults toward the east.

Resultant stress field at The Geysers responsible for (1) northwest-to-southeast oriented faults/fractures consistent with the San Andreas Fault System and (2) southwest-to-northeast oriented faults/fractures due to transtensional forces.

U.S. Geological Survey Faults

< 150 years

<15,000 years

<130,000 years

<1,600,000 years



California Department of Conservation
Division of Mines and Geology

kilometers

0 40 80


0 25 50

miles

N 23°E
Maximum Horizontal
Principal Stress S_{Hmax}




Seismic Monitoring Advisory Committee Meeting

Steam Production Well Targeting Constrained By Significant Steam Entry Alignment Correlation With Tracer Studies Is Very Encouraging ...



Seismic Monitoring Advisory Committee Meeting

Steam Production Well Targeting Constrained By Significant Steam Entry Alignment Correlation With Tracer Studies Is Very Encouraging ...



Seismic Monitoring Advisory Committee Meeting

Steam Production Well Targeting Constrained By Significant Steam Entry Alignment Correlation With Water Breakthrough Is Also Very Encouraging ...

This analysis/interpretation may also assist in better understanding potential (or existing) [water breakthrough](#)* from water injection wells to steam production wells along high permeability open fracture systems.


Aidlin Steam Production Wells With Confirmed Water Breakthrough

Aidlin-6: From Aidlin 11 and Aidlin 12 - Confirmed With Tracers

Aidlin-7: From Aidlin 11 - Due To Injection in 2007

Aidlin Steam Production Wells Watch Listed For Water Breakthrough

Aidlin-4 FK1/FK2: Aidlin 12 Injection Highly Affects NCG %



* Senior Geologist Melinda Wright provided information related to water breakthrough studies.

Seismic Monitoring Advisory Committee Meeting

Steam Production Well Targeting Constrained By Significant Steam Entry Alignment Correlation With Water Breakthrough Is Also Very Encouraging ...

This analysis/interpretation may also assist in better understanding potential (or existing) **water breakthrough*** from water injection wells to steam production wells along high permeability open fracture systems.

Steam Production Wells With Confirmed Water Breakthrough



DX-42: Due To DX-5 Injection (Casing Parted At 5111')

LF-35 OH: With LF-2 injection ≥ 350 gpm

LF-40 OH: With LF-15 injection ≥ 800 gpm

Steam Production Wells Shut-In Due To Water Breakthrough

DX-28 ST1: From DX-47 (?)



* Senior Geologist Melinda Wright provided information related to water breakthrough studies.


Seismic Monitoring Advisory Committee Meeting

Improved Water Distribution for Seismicity Mitigation


Conversion-To-Injection Drilling Program

Calistoga Power Plant Area

- | | | |
|----------|---------------|--|
| ○ 74F-21 | October 2019 | Conversion of Steam Production Well to Injection |
| ○ 87E-21 | November 2019 | Conversion of Steam Production Well to Injection |
| ○ 23C-22 | Early 2020 | Modification to Existing Water Injection |
| ○ 74E-21 | Early 2020 | Modification to Existing Water Injection |
| ○ 87G-21 | Early 2020 | Modification to Existing Water Injection |



Pre-Injection: Seismicity From 01 January 2005 Through 01 January 2020




Seismic Monitoring Advisory Committee Meeting

Detailed Analysis of CA74F-21 Water Injection and Seismicity Response


During Injection:

Additional Seismicity Through 13 May 2020



2020 Seismicity: 2X Black Symbols



74F-21 water injection is creating a relatively diffuse seismic response. However, on close inspection, the recharge area is overlapping with that of 74A-21 and extending further northward (as anticipated). When isolated from the background events, seismicity appears to be “illuminating” a nearly north-south striking and west dipping fracture/fault network.



Seismic Monitoring Advisory Committee Meeting

Detailed Analysis of GDC-34 Water Injection and Seismicity Response


Pre-Injection: Seismicity From 01 January 2005 Through 01 January 2020



Seismic Monitoring Advisory Committee Meeting



Detailed Analysis of GDC-34 Water Injection and Seismicity Response

During Injection: Additional Seismicity Through 13 May 2020



Seismic Monitoring Advisory Committee Meeting

New Prati-15 Water Injection Well Location




Pre-Injection: Seismicity From 01 January 2005 Through 15 January 2020




Seismic Monitoring Advisory Committee Meeting

Detailed Analysis of Prati-15 Water Injection and Seismicity Response

During Injection: Seismicity From 01 January 2005 Through 13 May 2020



Seismicity Animation; Two Week Intervals; 15 January 2020 To 13 May 2020 ONLY




Seismicity From 15 January 2020 To 13 May 2020 ONLY



Seismicity From 15 January 2020 To 13 May 2020 ONLY

Oblique View From Southwest



Seismic Monitoring Advisory Committee Meeting

Additional Seismic Monitoring and Research

California Energy Commission Electric Program Investment Charge (EPIC) Program EPC-16-021

Accepted Proposal

High-Resolution Micro-Earthquake Imaging of Flow Paths Using a Dense Seismic Network and Fast-Turnaround, Automated Processing * * Additional funding for this effort approved by the California Energy Commission in March 2020 *

Program Goal

Development of advanced, low-cost, microseismic imaging for high-resolution spatial and temporal images of subsurface fluid flow, flow barriers and heterogeneity in producing geothermal fields. The project will focus on microseismicity imaging challenges that are unique to geothermal reservoirs.

Improved 3D and time-lapse subsurface resolution is anticipated to assist with seismicity mitigation efforts at The Geysers.

Applicant

Lawrence Berkeley National Laboratory



Project Partners

Calpine Corporation

Array Information Technology

California Energy Commission Funds Recommended

\$1,672,639



Seismic Monitoring Advisory Committee Meeting

Additional Seismic Monitoring and Research

California Energy Commission Electric Program Investment Charge (EPIC) Program EPC-16-021


An extensive seismic sensor test program was planned and is being conducted with the project scientists. **Additional funding** for this effort approved by the CEC in March 2020.

Calpine Corporation has provided:


- The field location for this program.
- Technical support with survey design planning.
- On-site assessments including GPS surveying with updated equipment and techniques.
- Assistance to LBNL Contractor Ramsey Haught during 17 seismic sensor test installations.
- Coordination and updating of GPS surveys/maps data recovery at 2-3 month intervals.

Green Labeled Points

**Actual Installation Locations for
93 Sensor Station Installation Program.**
Not a uniform grid pattern due to extreme
topography and access concerns.



Surveying of 23 Test Sensor Station
Locations and Access Routes
Completed By Calpine With Samsung
Nexus 7 Tablet and Paired Garmin
GLO Device.



Generation Three Sensor Station



Sensor Installation on Rock Outcrop

